



Circuit Diagram No - Issue No

## TRANSFORMER VOLTAGE SELECTION



OT/LS - OPEN TORQUE/LIMIT SWITCH.

CT/LS - CLOSE TORQUE/LIMIT SWITCH.

1 OAS - OPEN AUXILIARY SWITCH.

CAS - CLOSE AUXILIARY SWITCH.

WIRES ARE IDENTIFIED AT EACH END BY  
TERMINAL NUMBER OR NUMBER SHOWN.

FS1 - 6.3A

| FS2 - 250mA

FS3 - 160mA


TERMINALS 4 & 5 FUSED

INTERNALLY AT 160mA

12W (MAX) HEATER FITTED AS STANDARD.

UNLESS OTHERWISE REQUESTED, HEATERS  
FITTED WILL BE :

120V (2K OHM) OR 240V (5.62K OHM).



Iss	Date	Chkd	Revision Details	www.rotork.com		Q-PAK + POT. + HEATER + C.P.T.		
03	220192	T.W	SIMILAR TO 1P32Q60 JOB NO --- SK1 & SK4 PIN NOD CORRECTED. CHECKED K.S.	ROTORK CONTROLS LTD BATH, BA1 3JQ ENGLAND Tel:01225-733200	ROTORK CONTROLS INC ROCHESTER NY 14624, USA Tel:585-247-2304	Drawn by: P.W. Date : 230590 Base WD: 1P32Q60 Job No : -- MI No :	Circuit Diagram No <b>1P32Q60</b>	Issue No <b>4</b>
04	270417	JS	FUSE RATING & TRANSFORMER VOLTAGE SELECTION CHANGED AS PER NEW PCB ECN / 7023					