

## Certificate of Compliance

**AWWA Standard for Rubber-Seated Butterfly Valves C504-10**

**AWWA Standard for Resilient-Seated Cast-Iron Eccentric Plug Valves  
C517-09**

### Manual Valve Actuators

Actuator Type:	IW5
Maximum Rated Torque:	4920 lbft
Ratios:	120:1, 80:1 and 40:1
Maximum handwheel size:	36 inches

This is to certify that the above-mentioned manual valve actuators are designed and tested to meet or exceed all the requirements of AWWA standard C504-10 and C517-09.

Test Report Reference:	T715, T729
Design File Reference:	AWWA C504-10 & C517-09, IW5 120:1

Signed:



Steve Watkins  
R&D Engineering Manager

Date of issue: 13<sup>th</sup> October 2011