

# Certificate of Compliance

**AWWA Standard for Rubber-Seated Butterfly Valves C504-10**

**AWWA Standard for Resilient-Seated Cast Iron Eccentric Plug Valves  
C517-09**

## Manual Valve Actuators

Actuator Type:	IW72
Maximum Rated Torque:	19177 lbft
Ratios:	360:1 and below
Maximum handwheel size:	36 inches, 360:1; 48 inches, 240:1 and below

This is to certify that the above mentioned manual valve actuators are designed and tested to meet or exceed all the requirements of AWWA standard C504-10 and C517-09.

Test Report Reference:	T1106, T1107 and T1162
Design File Reference:	AWWA C504-10 & C517-09, IW72 360:1

Signed:



Steve Watkins BEng CEng MIMechE  
R+D Engineering Manager

Date of issue: 19<sup>th</sup> October 2011