

Certificate of Compliance

AWWA Standard for Rubber-Seated Butterfly Valves C504-10

**AWWA Standard for Resilient-Seated Cast Iron Eccentric Plug Valves
C517-09**

Manual Valve Actuators

Actuator Type:	IW85
Maximum Rated Torque:	35477 lbft
Ratios:	720:1 and below
Maximum handwheel size:	36 inches, 720:1 and 540:1; 48 inches, 480:1 and below

This is to certify that the above mentioned manual valve actuators are designed and tested to meet or exceed all the requirements of AWWA standard C504-10 and C517-09.

Test Report Reference:	T1051, T1100 and T1223
Design File Reference:	AWWA C504-10 & C517-09, IW8 720:1

Signed:



Steve Watkins BEng CEng MIMechE
R+D Engineering Manager

Date of issue: 19th October 2011