

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	Rotork Controls Ltd
Address	Rotork House, Brassmill Lane, Bath, BA1 3JQ, United Kingdom
Type	Actuators
Description	IQ3 Range of Electric Actuators
Trade Name	IQ, IQM, IQML, IQL & IQH
Application	Marine, offshore and industrial use in the environmental categories ENV1 ENV2 as described in Lloyds Register Test Specification No1: July 2015
Specified Standard	Manufactures Specification EN60079-0, EN60079-1, EN60079-7, EN60079-31, EN13463-1, EN13465-5
Ratings	IP66 and IP68 ATEX II 2 GD, variant is available with the above IP rated actuators EAC TR CU 012/2011 certified variants are available with the above IP rated actuators 1-Phase 50/60 Hz, 100V to 240V 3-Phase 50/60 Hz, 200V to 690V Torque Range (Nm): 0 – 3000 Amps: 0 – 240 Output Rotation : 0deg. - 360deg. IQ, IQL, IQH Operating Time: 0 – 30 mins

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Matt Higgins

Senior Electrical Specialist to Lloyd's Register
EMEA
A member of the Lloyd's Register group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Type Approval Certificate

IQM, IQML Operating Time: Continuous
Gearcase Lubrication: Hydraulic/Synthetic EP Oil

Other Conditions This equipment shall be positioned such that the risk of impact to the window is low

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: 16/00065,16/00065(E1),LR2282604TA

The Design Appraisal Document LR2282604TA-01 and its supplementary Type Approval Terms and Conditions form part of this Certificate.