



1 EU-TYPE EXAMINATION CERTIFICATE

- 2 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 3 Certificate Number: Sira 03ATEX1253X
- 4 Equipment: EH 1.1 Actuator Control Module
- 5 Applicant: Rotork Controls Inc.
- 6 Address: 675 Mile Crossing Blvd Rochester New York 14624 United States of America
- 7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

Issue:

8

8 CSA Group Netherlands B.V., notified body number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN IEC 60079-0:2018 EN 60079-1:2014

EN IEC 60079-7:2015/A1:2018

- 10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.
- 11 This EU-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.
- 12 The marking of the equipment shall include the following:



Ex db* IIB T4 Gb

- Ta = -20 * * °C to +60 °C
 - "eb" is added to versions that have an increased safety enclosure
 - ** t may go down to -50°C



Signed: Michelle Halliwell

Title: Director of Operations

Project Number 80141826

This certificate and its schedules may only be reproduced in its entirety and without change CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands





EU-TYPE EXAMINATION CERTIFICATE

Sira 03ATEX1253X Issue 8

13 DESCRIPTION OF EQUIPMENT

The EH 1.1 Actuator Control Module is used for the remote positioning of hydraulically actuated process control valves. It is rated at 690 V a.c. with a maximum of 120 V a.c. or 60 V d.c. at the control circuit. It consists of a main cylindrical cast aluminium enclosure with a threaded top entry cover, a terminal housing and a hydraulic control block assembly.

The top entry cover is fitted with a window to allow the external observation of an internal LCD device. The window is manufactured from glass and is potted into a threaded housing, which in turn is screwed into the top entry cover.

The main enclosure houses PCBs, electrical control circuits and switches. There are two rotary control knob switch shafts and an indicator switch shaft, which pass through the wall of the main enclosure to form cylindrical flameproof joints. Additionally, there is threaded cable entry in the wall of the main enclosure.

The terminal enclosure provides all electrical field wiring terminations. It connects to the main enclosure by means of a spigoted flamepath joint and is secured by four M8 capscrews. The terminal housing is machined to take four threaded cable entries and is separated from the main enclosure by a terminal bung. The terminal bung comprises of a moulded plastic main body, through which passes a number of terminals that are sealed in place with a potting compound. The terminal enclosure is closed by means of a lid, which connects to the terminal enclosure by means of a spigoted flamepath joint and is secured by four M8 capscrews.

The hydraulic process pressure is sealed from the main enclosure by the hydraulic manifold block, which is secured to the main enclosure by means of a flanged flamepath joint and is secured by ten M8 capscrews. The hydraulic valve block utilises up to three solenoid valves with welded armatures, and a pressure sensor. The pressure sensor consists of welded metal diaphragm, the stresses in which, at maximum working pressure, are low enough as not to fail in service due to fatigue.

Variation 1 - This variation introduced the following changes:

- i. The extension of the ambient temperature range associated with the EH 1.1 Actuator Control Module was approved to be amended from -40°C to -50°C.
- ii. The option to fit a suitable blanking plug in place of the pressure switch was endorsed.

Variation 2 - This variation introduced the following changes:

- i. The introduction of an alternative manifold block that omits the pressure switch cavity.
- ii. The introduction of a blank manifold plate that replaces the manifold block.
- iii. The introduction of a blank manifold plate incorporating threaded cable entry points that replace the manifold block.

Variation 3 - This variation introduced the following change:

i. The revision of the certified nameplate was acknowledged.





EU-TYPE EXAMINATION CERTIFICATE

Sira 03ATEX1253X Issue 8

Variation 4 - This variation introduced the following changes:

- i. Following appropriate re-assessment to demonstrate compliance with the requirements of the EN 60079 series of standards, the documents previously listed in section 9, EN 50014:1997 (amendments A1 to A2), EN 50018:2000 (including amendment A1) EN 50019:2000 and EN 50281-1-1:1999, were replaced by those currently listed, the markings in section 12 were updated accordingly and the special condition for safe use was amended to recognise the new standards, the dust standard was removed from those shown.
- ii. The UK manufacturing site for this product has been removed from the certificate.
- iii. The introduction of an alternative pressure sensor.
- iv. The introduction of an alternative solenoid coils to replace obsolete items.
- v. The introduction of an alternative main PCB.
- vi. The introduction of an alternative indicator shaft retention method.
- vii. The introduction of a four way SPDT limit switches assembly.
- viii. The option to omit the two way SPDT limit switches was approved.
- ix. The recognition of minor drawing modifications for the purpose of clarification; these amendments are administrative or involve changes to the design that do not affect the aspects of the product that are relevant to explosion safety.

Variation 5 - This variation introduced the following changes:

- i. Modification to the drawing 83772
- ii. Modification to the drawing 83766
- iii. Following appropriate assessment to demonstrate compliance with the latest technical knowledge, EN 60079-0:2009 was replaced by EN IEC 60079-0:2018, EN 60079-1:2007 was replaced by EN 60079-1:2014 and EN 60079-7:2007 was replaced by EN 60079- 7:2015/A1:2018. The documents were updated accordingly to recognize the new standards.

14 DESCRIPTIVE DOCUMENTS

14.1 Drawings

Refer to Certificate Annexe.

14.2 Associated Reports and Certificate History

| Issue | Date | Report number | Comment |
|-------|-----------------------------------|-----------------|---|
| 0 | 06 November 2003 | R53A7563A | The release of the prime certificate. |
| 1 | 06 August 2004 | R53A7563A | Re-issued to correct changes to the thermal assessment and marking |
| 2 | 10 March 2005 | R53A7563K Rev 1 | Re-issued to correct the report number |
| 3 | 6 November 2003 10 March 2005 | R53A7563T | The introduction of Variation 1 |
| 4 | 06 November 2003 10 March 2005 | R53A7563Y | The introduction of Variation 2 |
| 5 | 06 November 2003 10 March 2005 | N/A | The introduction of Variation 3 |

Project Number 80141826

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands

DQD 544.09 Issue Date: 2022-04-14





EU-TYPE EXAMINATION CERTIFICATE

Sira 03ATEX1253X Issue 8

| Issue | Date | Report number | Comment |
|-------|-------------------|----------------|--|
| 6 | 14 February 2012 | R22749A/00-010 | This Issue covers the following changes: All previously issued certification was rationalised into a single certificate, Issue 6, Issues 0 to 5 referenced above are only intended to reflect the history of the previous certification and have not been issued as documents in this format. The introduction of Variation 4 |
| 7 | 02 September 2019 | 2399 | Transfer of certificate Sira 03ATEX1253X from Sira Certification Service to CSA Group Netherlands B.V. EC Type-Examination Certificate in accordance with 94/9/EC updated to EU Type-Examination Certificate in accordance with Directive 2014/34/EU. (In accordance with Article 41 of Directive 2014/34/EU. (In accordance with Article 41 of Directive 2014/34/EU. (In accordance prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Variations to such EC Type- Examination Certificates may continue to bear the original certificate number issued prior to 20 April 2016.) |
| 8 | 14 November 2022 | R80141827A | The introduction of Variation 5. |

15 SPECIFIC CONDITIONS OF USE (denoted by X after the certificate number)

15.1 In accordance with clause 5.1 of EN 60079-1, the critical dimensions of the flamepaths relevant to the EH 1.1 are:

| Flamepath | Maximum Gap (mm) | Minimum L (mm) |
|---|------------------|----------------|
| Manifold Block/Main Enclosure | 0.10 | 12.50 |
| Control Knob Shaft /Main Enclosure | 0.20 | 25.00 |
| Terminal Bung/Terminal Enclosure | 0.20 | 26.00 |
| Indicator Shaft Bushing/Main Enclosure | 0.00 | 25.25 |
| Indicator Shaft/Indicator Shaft Bushing | 0.20 | 31.75 |
| Terminal housing/Main Enclosure | 0.15 | 26.20 |
| Terminal Cover/Terminal Housing | 0.15 | 14.70 |

16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

17 CONDITIONS OF MANUFACTURE

17.1 The use of this certificate is subject to the Regulations Applicable to Holders of CSA Group Netherlands B.V. certificates.





EU-TYPE EXAMINATION CERTIFICATE

Sira 03ATEX1253X Issue 8

- 17.2 Holders of EU-Type Examination Certificates are required to comply with the conformity to type requirements defined in Article 13 of Directive 2014/34/EU.
- 17.3 When the termination facility is to be designed as "Ex eb", the following essential strength tests shall be applied to the termination facilities for at least 60 s and no more than 63 s as required by clause 6.1 of EN IEC 60079-7:2015/A1:2018.

| Test Voltage Applied Between | Test Voltage |
|---|--|
| Terminals with voltages of 90 V peak or greater | 1000 + 2U V_{RMS} $^{+5}$ ₀ % or 1500 V $_{RMS}$ $^{+5}$ ₀ % |
| and the case and lower voltage terminals. | whichever is greater (U being the supply voltage) |
| Terminals with voltages not exceeding 90 V peak | 500 V _{RMS} ⁺⁵ 0% |
| and the case | |

17.4 When an ambient temperature below -20°C and down to -40°C is specified, each device shall be subjected to a routine overpressure test in accordance with the table below. In all cases, the pressure shall be maintained for at least 10 s as required by clause 16 of EN 60079-1:2014. There shall be no permanent deformation or damage to the enclosure.

| Equipment | Hydrostatic Overpressure Test Pressure Applied | | |
|----------------------|--|---------------------|--|
| | Bar | Lbf/in ² | |
| Terminal Compartment | 15.38 | 223.0 | |
| Main compartment | 13.65 | 198.0 | |

17.5 When an ambient temperature below -20°C and down to -50°C is specified, each device shall be subjected to a routine overpressure test in accordance with the table below. In all cases, the pressure shall be maintained for at least 10 s as required by clause 16 of EN 60079-1:2014. There shall be no permanent deformation or damage to the enclosure.

| Equipment | Test Pressure | | |
|---|---------------|---------------------|--|
| | Bar | Lbf/in ² | |
| EH 1.1 Actuator Control Module Main Enclosure | 14.51 | 210.31 | |
| Eh 1.1 Actuator Control Module Terminal Compartment | 16.33 | 236.85 | |
| Terminal Bung | 16.33 | 236.85 | |

Certificate Annexe

| Certificate Number: | Sira 03ATEX1253X |
|---------------------|--------------------------------|
| Equipment: | EH 1.1 Actuator Control Module |
| Applicant: | Rotork Controls Inc. |



Issues 0 to 2 inclusive

| Drawing | Sheet | Rev. | Date | Title |
|-----------|--------|------|-----------|---|
| PLAD 1214 | 1 of 3 | 01 | 06 Aug 03 | Parts List For EH 1.1 Actuator Control Module, ATEX Group IIB |
| PLAD 1214 | 2 of 3 | 01 | 06 Aug 03 | Parts List For EH 1.1 Actuator Control Module, ATEX Group IIB |
| PLAD 1214 | 3 of 3 | 01 | 06 Aug 03 | Parts List For EH 1.1 Actuator Control Module, ATEX Group IIB |
| AD1214 | 1 of 3 | 01 | 06 Aug 03 | EH 1.1 Actuator Control Module, ATEX IIB Approval |
| AD1214 | 2 of 3 | 01 | 06 Aug 03 | EH 1.1 Actuator Control Module, ATEX IIB Approval |
| AD1214 | 3 of 3 | 01 | 06 Aug 03 | EH 1.1 Actuator Control Module, ATEX IIB Approval |
| 77470-04 | 1 of 1 | 04 | 30 Jun 03 | Nameplate EH Roch ATEX Gp IIB – 40 to 60 |
| 77564-03 | 1 of 1 | 03 | 10 Jun 03 | Nameplate EH Roch ATEX Gp IIB – 20 to 60 |
| 77565-03 | 1 of 1 | 03 | 10 Jun 03 | Nameplate EH Bath ATEX Gp IIB – 40 to 60 |
| 77566-03 | 1 of 1 | 03 | 10 Jun 03 | Nameplate EH Bath ATEX Gp IIB – 20 to 60 |
| 44210 | 1 of 1 | 1 | 07 Aug 00 | Label Conduit Entry – NPT |

Issue 3

| Drawing | Sheet | Issue | Date | Title |
|-----------|--------|-------|-----------|---|
| PLAD 1214 | 1 of 3 | 02 | 18 Feb 05 | Parts List For EH 1.1 Actuator Control Module, ATEX Group IIB |
| PLAD 1214 | 2 of 3 | 02 | 18 Feb 05 | Parts List For EH 1.1 Actuator Control Module, ATEX Group IIB |
| PLAD 1214 | 3 of 3 | 02 | 18 Feb 05 | Parts List For EH 1.1 Actuator Control Module, ATEX Group IIB |
| AD1214 | 1 of 3 | 02 | 18 Feb 05 | EH 1.1 Actuator Control Module, ATEX IIB Approval |
| AD1214 | 2 of 3 | 02 | 18 Feb 05 | EH 1.1 Actuator Control Module, ATEX IIB Approval |
| AD1214 | 3 of 3 | 02 | 18 Feb 05 | EH 1.1 Actuator Control Module, ATEX IIB Approval |
| 78121-01 | 1 of 1 | 01 | 20 Dec 04 | Nameplate EH Bath ATEX Gp IIB – 50 to 60 |
| 78122-01 | 1 of 1 | 01 | 20 Dec 04 | Nameplate EH Roch ATEX Gp IIB – 50 to 60 |

Issue 4

| Number | Sheet | Rev. | Date | Title |
|-----------|--------|------|-----------|---|
| PLAD 1214 | 1 of 4 | 03 | 19 May 05 | Parts List For EH 1.1 Actuator Control Module, ATEX Group IIB |
| PLAD 1214 | 2 of 4 | 03 | 19 May 05 | Parts List For EH 1.1 Actuator Control Module, ATEX Group IIB |
| PLAD 1214 | 3 of 4 | 03 | 19 May 05 | Parts List For EH 1.1 Actuator Control Module, ATEX Group IIB |
| PLAD 1214 | 4 of 4 | 03 | 19 May 05 | Parts List For EH 1.1 Actuator Control Module, ATEX Group IIB |
| AD1214 | 1 of 4 | 03 | 18 May 05 | EH 1.1 Actuator Control Module, ATEX IIB Approval |
| AD1214 | 2 of 4 | 03 | 18 May 05 | EH 1.1 Actuator Control Module, ATEX IIB Approval |
| AD1214 | 3 of 4 | 03 | 18 May 05 | EH 1.1 Actuator Control Module, ATEX IIB Approval |
| AD1214 | 4 of 4 | 03 | 18 May 05 | EH 1.1 Actuator Control Module, ATEX IIB Approval |

Issue 5

| Number | Sheet | Rev. | Date (Sira stamp) | Title |
|----------|--------|------|-------------------|--|
| 77470-06 | 1 of 1 | 06 | 10 Apr 08 | Nameplate EH Roch ATEX Gp IIB – 40 to 60 |
| 77564-05 | 1 of 1 | 05 | 10 Apr 08 | Nameplate EH Roch ATEX Gp IIB – 20 to 60 |
| 77566-05 | 1 of 1 | 05 | 10 Apr 08 | Nameplate EH Bath ATEX Gp IIB – 20 to 60 |
| 78122-03 | 1 of 1 | 03 | 10 Apr 08 | Nameplate EH Roch ATEX Gp IIB – 50 to 60 |

Project Number 80141826 This certificate and its schedules may only be reproduced in its entirety and without change CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands

Certificate Annexe

| Certificate Number: | Sira 03ATEX1253X |
|---------------------|--------------------------------|
| Equipment: | EH 1.1 Actuator Control Module |
| Applicant: | Rotork Controls Inc. |



Issue 6.

| Drawing | Sheets | Rev. | Date (Stamp) | Title |
|----------|--------|------|--------------|---|
| 83766 | 1 of 1 | 02 | 13 Feb 12 | Nameplate, EH Roch ATEX & IECEx |
| 83772 | 1 to 8 | E | 13 Feb 12 | EH1.1 (pro) Control Module – ATEX & IECEx Approval Dwg |
| 84109 | 1 of 1 | 03 | 13 Feb 12 | Assembly, Shaft Collar |
| 46935 | 1 of 1 | 1 | 13 Feb 12 | Warning Label |
| DOC 1912 | 1 of 1 | 01 | 13 Feb 12 | EH1.1 Terminal Housing O Ring Specification |

Issue 7. No new drawings were introduced

Issue 8

| Drawing | Sheets | Rev. | Date (Stamp) | Title |
|---------|--------|------|--------------|---|
| 83766 | 1 of 1 | 07 | 25 Oct 22 | NAMEPLATE, EH ROCH ATEX & IECEX |
| 83772 | 1 to 8 | 05 | 25 Oct 22 | EH 1.1 (PRO) CONTROL MODULE - ATEX & IECEX APPROVAL |
| | | | | DWG |