



RC200 Pneumatic Actuators

Instruction

Type and Design

DA = Double Acting. Actuator with pneumatic operation in both directions.

SR = Spring Return. Actuator with spring return. RC 210, 230, 250 and 270 have 1 piston.

RC 220, 240, 260 and 280 have 2 pistons.

Operating Medium

If the operating medium is instrument air, it shall be dust and oil-free. Accepted operating medium: Non-dangerous fluids (group 2 according to directive 97/23/EC). The dew point shall be equal to $-20~^{\circ}\text{C}$ or, at least, 10 $^{\circ}\text{C}$ below the ambient temperature. The maximum particle size must not exceed 40 μm . The exhaust air must pass through a filter silencer before it is let out into the workshop.

The Application of the Scotch Yoke Construction

The Scotch Yoke of the RC200 actuators has canted slots. Thus the actuator can be given different function depending on how the pistons are mounted in the actuator. The pistons are mounted according to Fig.1, page 4, or Fig.1a, in order to achieve the following functions.

According to Fig.1:

DA-Actuator with adjustable closed valve position (clockwise end of travel).

SRF-Actuator with spring opening (counter clockwise direction), adjustable "closed" valve position (clockwise end of travel).

According to Fig.1a:

DAAO-Actuator with adjustable open valve position (counter clockwise end of travel).

SR-Actuator with spring closing (clockwise direction), adjustable "open" valve position (counter clockwise end of travel).

The possibility to turn the pistons can be used in several ways in order to suit the actuators to the customer's requirements.

WARNING!

RC actuators must only be used as actuators on valves. Levers, racks and similar cannot be used to transmit movement without protective equipment. Pinch risk in the valve opening when test trimming non-installed valves.

Manual Operation

WARNING!

It is very risky to try to operate the actuator manually by using the key grip on the driving shaft. The accumulated energy inside the actuator may instantaneously be set free.

The actuator can be equipped with handwheel for manual operation, RC-M. Other methods on request.

WARNING!

All manual operations must be carried out with a pressureless actuator.

Installation and Adjustment

All types of actuators can be mounted in various positions, e.y. vertical or horizontal. When mounting on a valve, ensure that the actuator shaft and the valve stem are centered, and that a play of 0,5-1 mm exists between shaft and driving bush depending on actuator size. Ensure especially that actuator and driving bush are mounted correctly in relation to eachother, considering that the actuator shaft has an octagonal hole and that a faulty mounting of 45° is possible. This naturally also applies to direct mounting on a valve. The guide ring (37) can be dismantled when not in use. After mounting, it may be necessary to adjust the turning angle of the actuator.

Tightening torques for lock nuts on page 6.

As mentioned previously, the DA actuators can, as standard, be adjusted in "closed" valve position and the SR actuators in "open" position. The adjustment occurs by loosening the lock nut on the end plate, after which the set screw is turned clockwise for reduced and anti-clockwise for increased rotary motion. The adjustment degree is $\pm 3^{\circ}$. RC220, 240, 260 and 280 have two adjustment screws.

It is important that *both* screws are in contact with the piston in question.

The actuator is supplied with an indicator on the driving shaft. The indicator can be mounted in 2 optional positions for different valve functions, mounting directions, etc.



Specific condition of use

Actuators intended to be used in hazardous areas are limited in accordance with the Ex marking on actuator sticker. Avoid placing actuator in direct sunlight, due to the risk of increased temperature. Especially for actuator in hazardous areas.

The temperature of the actuator control medium shall be the same as the ambient temperature in hazardous areas. If actuator is used on equipment with heavy dynamic parts without built in mechanical stop, the energy transmitted to the actuator has to be considered. If used in hazardous areas the system must be in consideration with respect to the limitations for impact energy according to valid Ex standards.

Mechanical generated spark, avoid any accidental impact on the equipment or friction in the equipment parts containing light metals.

The actuator shall not have any dust layers during its normal operation and expected malfunction Operating medium, see page 1.

For RC...-SR... actuators, filter-dust excluder IP6X must be mounted for the venting side of the actuator, either in the venting port or in the direct mounted solenoid valves venting port.

Note

Dust and debris accumulated on the actuator will slow down its cooling and contribute to increase of its external temperature

Prevent electrostatic discharge

Do not polish/rub nonmetallic surface with a dry cloth. The tools and the cleaning procedures must not produce sparks or crate adverse condition in the environment during maintenance operations, so as to prevent potential explosion hazards. Prevent electrostatic charges in potentially explosive areas.

ELECTROSTATIC RISK

There is a potential electrostatic charging hazard associated with nonconductive paint and therefore actuator must only be cleaned with a damp cloth.

Prevent electrostatic charges in potentially explosive areas – do not polish/rub nonconductive surfaces with a dry cloth, the operator's clothes must not be electrostatically charged. The tools and cleaning procedures must not produce sparks or create adverse conditions in the environment during maintenance operations, so as to prevent potential explosion hazards. The user must ensure that the operating environment and any materials surrounding the actuator cannot lead to a reduction in the safe use of, or the protection afforded by, the actuator.

Where appropriate the user must ensure the actuator is suitably protected against its operating environment.

The user must plan a regular equipment surface cleaning maintenance for example with a damp cloth every 6 month as minimum, recommended due to the dustiness of the environment, if possible decrease the cleaning frequency.

Actuator type									
	ard RC C to 75 °C	Viton -15 °C to 75 °C		High temp 0 °C to 150 °C		Low temp -40 °C to 55 °C		Low temp. arctic -47 °C to 55 °C	
T amb (°C)	T Class	T amb (°C)			T Class	T amb (°C)	T Class	T amb (°C)	T Class
55	T6	55	T6	55	T6	55	T6	55	T6
75	T5	75	T5	70	T5				
				105	T4				
				150	Т3				
Actuator w	ith manual o	verride M1 r	nax ambient						



IECEx DNV 21.0039X / DNV 21 ATEX 94178X C € 0470 **(**

RC II 2 G Ex h IIC Gb T6/T5 -20°C to +55°C/+75°C

II 2 D Ex h IIIC Db T79 / T99

RC V II 2 G Ex h IIC Gb T6/T5 -15°C to +55°C/+75°C

II 2 D Ex h IIIC Db T68 / T88

RC HT II 2 G Ex h IIC Gb T6/T5/T4/T3 0°C to +55°C/+70°C/+105°C/+150°C

II 2 D Ex h IIIC Db T68 / T88 / T118 / T163

RC LT II 2 G Ex h IIC Gb T6 -40°C to +55°C

II 2 D Ex h IIIC Db T79

RC LTA II 2 G Ex h IIC Gb T6 -47°C to +55°C

II 2 D Ex h IIIC Db T79

Note! When actuator is equipped with manual override M1 Max ambient temperature 70 °C is allowed.

Lubrication

RC actuators are permanently lubricated, and additional lubrication is normally not required. However, during frequent operation and heavy load it's recommended to use oil mist lubrication or regrease once every year / or 100 000 cycles whatever appears first.

For oil mist lubrication is a mineral oil type ISO VG32 according to DIN 51524HLP recommended. Oil mist lubricator should be set at lowest possible value that allows effective lubrication of the actuator. Commenced oil mist lubrication must continue.

To regrease actuator, follow the instruction "Service of RC210-280" page 4.

Note! If external accessories like pneumatic or electropneumatic positioner etc. is mounted to the actuator, check the accessories data sheet if oil mist is allowed.


Recommended Lubrication Grease							
Cylinder bore and drive shaft with shaft sealings	Grease						
RC200 Standard	Klübersynth AR 34-402						
RC200 high temp	Klübertemp HM 83-402						
RC200 low temp	Klüber Isoflex Topas NCA 52						

Piston roller (21) + bearing	Grease				
All RC200	Cargo Red Grease				

Oil mist lubrication and grease containing polyglycole, ester or other aggressive additives shall be avoided.



Fig. 1



Dwg.no.021446

Service of RC210-280

WARNING!

Before dismantling the actuator, check that the possible power supply and the operating medium are disconnected, and the actuator is pressureless. Dismantling of SR unit, see instruction on page 7. Dismantling of SR unit with manual operation unit

Exchange of Piston Sealings and Support Elements

- 1. Please read the warning above!
- 2. Dismantle the actuator from the console.
- 3. Dismantle the end plates (5) or the spring packs (25).
- 4. Fasten the actuator shaft between soft jaws in a vice and turn the actuator until the pistons reach the cylinder end. Then place a few rods in the holes on the outside of one piston. By pressing together and pulling these rods simultaneously, the piston is dismantled from the cylinder.
- 5. If the piston O-ring (12) is worn, it must be replaced.
- 6. Replace the support band (14) if it is worn.
- 7. Replace the support element (9) if it is worn.
- 8. Grease the cylinder surface with a grease according to the lubrication list on page 3.
- 9. Fit piston/s correctly positioned, see "The Application of the Scotch Yoke construction" on page 1.
- 10. Fit the end plate/s or spring pack/s and adjust the shaft turning angle.

Exchange of Shaft Sealings and Support Washers

The O-rings (18) and (38) and the support washers (33) and (39) can easily be replaced as below.

- 1. Please read the warning on the left!
- 2. Dismantle the actuator from the console.
- 3. Dismantle the retaining rings (31) and (40) around the shaft.
- 4. Dismantle the worn details.
- 5. Fit the new O-rings (18) and (38).
- 6. Fit new washers under the retaining rings.
- 7. Use a grease according to the lubrication list on page 3 when mounting.
- 8. Fit the new retaining rings.
- 9. Check that the retaining rings are tightly fitted without play in their grooves.

Exchange of Shaft Bearings

The bearings (16) and (36) and also the support ring (19) and (35) are of sliding rotating type. When the pistons and shaft sealings are dismantled, the bearings and support rings shall be checked and replace if they are worn.

Note! For exchange of the support ring (35) and for actuator size RC..270-.... and larger contact the supplier.

For repair kits all sizes and variants contact the supplier.



Part No	Description	Description Number SR Material ⁷		Surface treatment		
1	Adjusting screw ¹	1	-	Size 210–260: Stainless steel Others: Steel	- Zinc plated	
2	Lock nut ¹	1	-	Size 210–260: Stainless steel Others: Steel	Zinc plated	
3	O-ring ^{1,6}	1	-	Nitrile	-	
4	Screw	8-16	8-16	Size 210–260: Stainless steel Others: Steel	Zinc plated	
5	End plate with centre hole ¹	1	-	Aluminium	Anodized Powder coated	
6	O-ring ⁶	2	2	Nitrile	-	
7	Cylinder	1	1	Aluminium	Anodized	
8	Scotch Yoke	1	1	Steel	-	
9	Support element ^{1,6}	1	1	POM	-	
10	Piston ¹	1	1	Aluminium	-	
11	Roll pin, double ^{2,3}	1	1	Spring steel	-	
12	O-ring ^{1,6}	1	1	Nitrile	-	
14	Support band ^{1,6}	1	1	Polymer material	-	
15	Driving shaft	1	1	Size 210–260: Stainless steel Others: Steel	- Zinc plated, yellow chromated	
16	Bearing, upper	1	1	Polymer material	-	
17	End plate without centre hole⁴	1	1	Aluminium	Anodized Powder coated	
18	O-ring, upper ⁶	1	1	Nitrile	-	
19	Support ring, upper	1	1	Polymer rmaterial	-	
20	Piston pin ¹	1	1	Steel	-	
21	Piston roller ¹	1	1	Steel	-	
22	Spring guide ¹	-	1	Aluminium	-	
23	Spring, external ¹	-	1	Alloyed spring steel	Corrosion protected	
24	Spring, internal ^{1,5}	-	1	Alloyed spring steel	Corrosion protected	
25	Spring housing ¹	-	1	Aluminium	Anodized Powder coated	
26	Pre-tensioning screw ¹	-	1	Size 210–260: Stainless steel Others: Steel	- Zinc plated	
27	Indicator	1	1	Polymer material	-	
28	O-ring ^{1,6}	-	1	Nitrile	-	
29	Lock nut ¹	-	1	Size 210–260: Stainless steel Others: Steel	- Zinc plated	
30	Marking washer ¹	-	1	Aluminium	Anodized	
31	Retaining ring, upper ⁶	1	1	Spring steel	Corrosion protected	
32	Middle washer ⁶	1	1	Stainless steel	-	
33	Support washer, upper ⁶	1	1	Polymer material, chemically resistant	-	
34	Sealing ¹	1	1	Size 210–240: Stainless steel Others: Nitrile	-	
35	Support ring, lower	1	1	Polymer material	-	
36	Bearing, lower	1	1	Polymer material	-	
37	Guide ring	1	1	Polymer material	-	
38	O-ring, lower ⁶	1	1	Nitrile	-	
39	Support washer, lower ⁶	1	1	Polymer material, chemically resistant	-	
40	Retaining ring, lower ⁶	1	1	Spring steel	Corrosion protected	

¹⁾ For actuator sizes 220, 240, 260 and 280: The double amount of details. 2) RC240 has triple roll pins. 3) RC270–280 have a slotted pin in steel. 4) Not in the picture! Do not exist for sizes 220, 240, 260 and 280. 5) For size 230-280. 6) Included in seal kit. 7) For standard versions, for other versions consult Rotork.




Fig. 3

Converting to SR Actuators

All DA actuators can be changed into SR actuators by adding spring conversion kits according to the following instruction:

- 1. Please read the warning on page 4!
- 2. Dismantle the end plates. (The description is for RC220, 240, 260 and 280 which have two pistons).
- 3. Dismantle the pistons. See text under "Exchange of piston sealings and support elements" on page 4.
- 4. Mount the pistons according to figure 1a on page 4.
- 5. Check that the spring is correctly pre-tensioned according to table 1 and figure 2.
- 6. The spring guide (22) is centered towards the piston with the aid of 2 pins.
- 7. The SR units on sizes 230–280 must be turned so that one of the three support points lies between the bosses on the piston (10).
- Mount the SR unit when the pistons are in their innermost position.
- Put the screws (4) in place. When tightening the screws, the spring force is transmitted from the tensioning screw (26) to these screws.
 - Tightening torques according to table on page 8.
- 10. The turning angle of the actuator is adjusted with the tensioning screw (26).



Adjustment is made with screw (26).

Table 1						
RC200-SR actuator	Α					
RC210-220	41					
RC230-240	62					
RC250-260	87					
RC270-280	137					


Instructions for Dismantling of RC200-SR Actuators with Manual Operation Unit Type M1

WARNING!

Do not remove the protective tube (50) and handwheel from the spring housing as long as the springs are tensioned. This procedure must be followed for safe dismantling of pre-tensioned spring housings.

- 1. The actuator must be pressureless.
- Check that the springs can press the piston back into its starting position according to figure 3.The upper shaft journal must not be oblique.
- 3. Disconnect possible power supply.
- Turn the handwheel so that the threaded stem (51) moves toward the actuator until it stops and the yellow marker (68) can just barely be seen in the plastic tube (49).
- 5. For sizes RC220, 240, 260 and 280 (i.e. actuators with two pistons): adjust the tensioning screw (26) in the opposite spring housing anti-clockwise until it lies against the spring guide (22). Dismantle the spring housing by loosening the screws (4).
- For all sizes: then turn the handwheel until there is resistance and the yellow marker (68) can be seen within the "AUTO" position.
- 7. Dismantle the spring housing of the manual override by loosening the retaining screws (4) and turning the handwheel several turns in the direction which gives the least resistance.


Dismantling must be carried out in the above order with the utmost care. In the case of the slightest uncertainty - contact the supplier.





Instructions for Dismantling of RC200-SR Actuators

RC 210, 230, 250 and 270




WARNING!

The procedure below must be followed for safe dismantling of pretensioned spring housings.

- 1. The actuator must be pressureless.
- 2. Check that the springs can press the piston into starting position according to figure 4.
- 3. Disconnect all possible power supply.
- 4. Loosen the lock nut (29).
- 5. Turn the tensioning screw (26) anticlockwise until it lies lightly against the spring guide (22).
- 6. Dismantle the spring housing by loosening the screws (4).
- 7. Dismantling must be carried out with the utmost care. In the case of the slightest uncertainty contact the supplier.

RC 220, 240, 260 and 280



WARNING!

The procedure below must be followed for safe dismantling of pretensioned spring housings.

- 1. The actuator must be pressureless.
- Check that the springs can press the piston into starting position according to figure 5.
- 3. Disconnect all possible power supply.
- 4. Loosen the lock nuts (29).

Fig. 5

- 5. Turn both spring tensioning screws (26) clockwise until they lies lightly against the spring guides (22).
- 6. Turn the left spring tensioning screw (26) anti-clockwise until it lies lightly against the spring guide (22) and dismantle the left spring housing by loosening the screws (4).
- 7. Dismantle the right spring housing in the same manner as the left one.
- Dismantling must be carried out with the utmost care. In the case of the slightest uncertainty - contact the supplier.




Tightening Torques for Screws and Lock Nuts

The actuators must be screwed onto the console with the correct tightening torque in order

to remain stable during operation. Please use as long screws as possible without the

threads grounding.



"L" is the screw-in length according to drawing.

Tightening Torques Nm								
Actuator	Screw (4)	Lock nut DA (2)	Lock nut SR (29)					
RC210-220	4	17	7					
RC230-240	4	33	17					
RC250-260	17	90	33					
RC270-280	76 55¹	120	120					


¹⁾ Tightening torque with Stainless steel screw. A2 70 quality.

Resistance class min. 8.8. Lightly oiled screws.

Tightening Torques Nm													
Actuator	DIN	Thread	L max	Screw-in length (mm)									
Actuator	flange	Tilleau	eau (mm)		10	12	14	16	18	20	24	28	32
RC210-220	F05	M6	11	8,8	9,2	-	-	-	-	-	-	-	-
RC210-220	F07	M8	14	-	21	23	23	-	-	-	-	-	-
RC230-240	F07	M8	14	-	21	23	23	-	-	-	-	-	-
RC230-240	F10	M10	17	-	-	40	45	45	-	-	-	-	-
RC250-260	F10	M10	17	-	-	40	45	45	-	-	-	-	-
RC250-260	F12	M12	21	-	-	-	60	70	75	75	-	-	-
RC270	F14	M16	25	-	-	-	-	125	140	155	185	-	-
RC270	170x110	M16	25	-	-	-	-	125	140	155	185	-	-
RC280	F12	M12	25	-	-	-	-	70	75	75	75	-	-
RC280	F16	M20	32	-	-	-	-	-	-	-	280	330	360
RC280	F25	M16	25	-	-	-	-	125	140	155	185	-	-

Air Connections

Double Acting



\$

DA DATP

OCCW CCW CW

SR SRF

Reversed direction of rotation


Single Acting with Spring Return

Air CCW rotation Spring CW rotation


Air CW rotation Spring CCW rotation

RC..250-280 all types

RC..210-240 all types



Hole pattern for solenoid valves acc, to EN 15714-3




^{*1} BSP threads standard, NPT threads indicated with letter N on the actuator sticker for RC200 with all other threads metric.



RC... Quick actuator

RC...-..Q.. actuator is used there faster operating time is requested. One quick version is the semi quick that has enlarged holes in the connection ports for the solenoid valve. The version with larger connections, has extra holes in cylinder, endplates or spring house depending on actuator function, see figure below.




Dimension, thread type and number of hole for medium connection can be found on the RC...-...Q actuator sticker.

RC... Hydraulic actuator

Hydraulic actuators has venting nipples on the actuator. The venting nipples may be placed in different positions depending on actuator mounting orientation. For venting of the pressurized actuator, use PPE and protect the surroundings from spillage.


For opening and closing of the venting nipples, use the supplied key.


Example for venting nipple positions.





RC210-240 RC250-280






Dwg.no.021205

	Dwg.no.021205			
Mater	ial Table for RC210-280	M1 7		
Part No	Description	Number	Material ⁷	Surface treatment
10M	Piston M	1	Aluminium	-
22M	Spring guide M	1	Aluminium	-
0514				Anodized
25M	Spring housing M	1	Aluminium	Powder coated
41	Needle roller bearing RC250-280	1	Ball bearing steel	-
42	O-ring ⁶	1	Nitrile	-
43	Needle roller bearing RC250-280	1	Ball bearing steel	-
43	Slide bearing RC210-240	1	Bronze	-
44	Cuff sealing	1	Nitrile/Steel	Zinc plated
45	Key	1	Steel	-
40	Head bank		Aluminium	Anodized
46	Handwheel	1	RC280: Steel	Powder coated
47	Set screw 8	1	Stainless steel	-
48	O-ring ⁶	1	Nitrile	-
49	Tube, transparent	1	Acrylic Plastic	-
50	Protecting tube	1	Aluminium	Anodized
51A	Stem, DA (right threaded)	1	Steel	-
51B	Stem, SR (left threaded)	1	Steel	-
52	Spring	1	Stainless spring steel	-
53	Locking hook	1	Stainless steel	-
54	Tredo-sealing ⁶	2	Nitrile/Steel	Zinc plated
55	Spacer, RC210-260	1	Stainless steel	-
56	Screw, RC210-260	1	Stainless steel	-
57	Spring Holder	1	Stainless steel	-
58	Screw	1	Steel	Zinc plated
59	O-ring, RC210-240 ⁶	1	Nitrile	-
61	Screw	2	Steel	Zinc plated
62A	Stem nut, DA (right threaded)	1	RC210-240: Brass	-
			RC250-280: Ductile iron	Zinc plated
62B	Stem nut, SR (leaft threaded)	1	RC210-240: Brass	-
			RC250-280: Ductile iron	Zinc plated
63	Retaining ring, RC250-280	1	Steel	Corrosion protected
64	Handwheel bushing, RC250-280	1	Aluminium	Anodized
65	Key	1	Steel	-
66	Screw, RC250-280	1	Steel	Zinc plated
67	Label	1	Polymer material	-
68	Indication ring	1	Polymer material, yellow	-

6) Included in seal kit 7) For standard versions, for other versions consult Rotork 8) For actuator size 270 and 280: The double amount of details



Function RC-M1




(10M)


Neutral Position

With the stem (51) in Auto position, the piston (10M) can move freely and the actuator can be operated pneumatically. The picture shows a double acting actuator, DA, in "open" position or a single acting actuator, SR, in "closed" position.

End Position Adjustments

M1 in Auto position works as an end position stop. DA: Adjustment of closed valve position. SR: Adjustment of open valve position. Adjustment degree: +3° / –90° in relation to the end position.





Manual Operation

DA: The handwheel (46) is turned anti-clockwise. The stem (51) and piston (10M) are pressed inwards. The valve opens.

SR: The handwheel is turned clockwise. The stem and piston are pressed inwards. The valve closes.

Manual Operation

DA: The handwheel is turned clockwise. The stem and piston are drawn outwards. The valve closes. SR: The handwheel is turned anti-clockwise. The stem and piston are drawn outwards. The valve opens.


The actuator (15) shaft is thus turned in the same direction as the handwheel.

When the actuator has been operated manually, a return to the Auto position must take place before remote operation can be performed again.

On dismounting the manual operation housing (25M), the actuator **must** first be ventilated, for SR actuators the stem (51) **must** also be in Auto position.



Note! RC..280-SRM.. Hand wheel is not assembled at delivery, due to space saving



Dwg. no. 130053

Before the actuator is ready for operation, the handwheel and protecting tube have to be mounted acc. to following instruction.

Dismantle circlip (63) from handwheel bushing (64) by using circlip pliers.

Mount protecting tube (50) by turning it clock-wise on stem nut (62). For right bearing clearance, tighten the tube until handwheel bushing (64) can only just be turned by hand. Lock the stop screws (47). Place handwheel (46) onto handwheel bushing, and fit circlip (63) back into groove with circlip pliers. Adjust with handwheel so that indication (51) is in auto position mark on protecting tube. Pressurize actuator in left supply port with 50-60 % of nominal air pressure, actuator will now make a rotary motion to open position Adjust handwheel until a position is found where stem meets piston. At this position both pistons will be engaged as end stops. When position is found, mount locking hook (53) onto handwheel rim



Rotork Sweden AB Box 80, Kontrollvägen 15 SE-791 22 Falun SWEDEN Tel +46 (0)23 587 00

Fax +46 (0)23 587 45

We reserve the right to make changes without notice.